



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 397

Customer

Facility Name: Oliver Bath House
Address: 38 S. 10th St.
Pittsburgh, PA 15203

Sample Collection

Date: 7/29/26
Time: 10:15 AM
Method: Grab

Matrix: Recreational Water

Source Type: Deep End

Sample Final Analysis

Date: 8/1/26
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/26	8:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/26	8:30 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/26	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/29/26	10:15 AM	WB	DPD
Chlorine:	4.5 mg/l	1.0 - 5.0 mg/l	7/29/26	10:15 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/26	10:15 AM	WB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)