



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 2030

Customer

Facility Name: Barrington Manor

Address: 200 Barrington Dr.
Oakdale, PA 15071

Sample Collection

Date: 6/30/26
Time: 7:49 AM
Method: Grab

Matrix: Recreational Water

Source Type: Pool

Sample Final Analysis

Date: 7/2/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/26	10:30 AM	AH	SM 9222B
Standard plate count:	10/ml	200/ml	6/30/26	4:45 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/30/26	7:49 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/30/26	7:49 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/26	7:49 AM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)