



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2043**

**Customer**

**Facility Name:** *Blackridge Swim Club*

**Address:** *1200 Beulah Rd*  
*Pittsburgh, PA 15221*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Collection**

**Date:** *6/29/26*

**Time:** *11:03 AM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *7/1/26*

**Time:** *1:00 PM*

**Analyst:** *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/30/26              | 12:30 PM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/30/26              | 12:30 PM | AH      | SM 9222B |
| Standard plate count: | 25/ml    | 200/ml          | 6/29/26              | 6:30 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.0 SU   | 7.2 - 7.8 SU    | 6/29/26   | 11:03 AM | DW      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 6/29/26   | 11:03 AM | DW      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/29/26   | 11:03 AM | DW      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor