



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2097**

**Customer**

**Facility Name:** Chartiers Valley C.C.

**Address:** 601 Baldwin Road  
Pittsburgh, PA 15205

**Matrix:** Recreational Water

**Source Type:** Deep End

**Sample Collection**

**Date:** 7/1/26

**Time:** 9:30 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/3/26

**Time:** 11:00 AM

**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/2/26     | 10:30 AM  | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/2/26     | 10:30 AM  | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/1/26     | 4:20 PM   | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit |        | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 7/1/26 | 9:30 AM   | VH      | DPD    |
| Chlorine:      | 1.0 mg/l | 1.0 - 5.0 mg/l  | 7/1/26 | 9:30 AM   | VH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/1/26 | 9:30 AM   | VH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor