



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 066

Customer

Facility Name: Comfort Suite
Address: 750 Aten Rd.
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/30/26
Time: 10:38 AM
Method: Grab

Sample Final Analysis

Date: 7/2/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/26 10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/26 10:30 AM	AH	SM 9222B
Standard plate count:	250/ml	200/ml	6/30/26 4:45 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/30/26 10:38 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/30/26 10:38 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/26 10:38 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor