



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 063

Customer

Facility Name: *Comfort Inn - Meadowlands*

Address: *237 Meadowlands Boulevard
Washington, PA 15301*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/30/26*

Time: *9:08 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/2/26*

Time: *1:00 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/26	12:30 PM	AH	SM 9222G
Total coliforms:	2/100mls	2/100mls	7/1/26	12:30 PM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	6/30/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/30/26	9:08 AM	JMH	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	6/30/26	9:08 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/26	9:08 AM	JMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)