



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 447

Customer

Facility Name: Fox Chapel High School

Address: 611 Field Club Rd
Pittsburgh, PA 15238

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 6/29/26

Time: 10:50 AM

Method: Grab

Sample Final Analysis

Date: 7/1/26

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/30/26	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/30/26	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/29/26	3:11 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/29/26	10:50 AM	LL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/29/26	10:50 AM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/0/00	10:50 AM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor