



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 109

Customer

Facility Name: Gateway High School
Address: 3000 Gateway Campus Blvd.
Monroeville, PA 15146

Sample Collection

Date: 6/30/26
Time: 10:21 AM
Method: Grab

Matrix: Recreational Water
Source Type: Shallow End

Sample Final Analysis

Date: 7/2/26
Time: 1:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/26	1:00 PM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/26	1:00 PM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/26	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/30/26	10:21 AM	DW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/30/26	10:21 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/26	10:21 AM	DW	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)