



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**W-13**

**Lab# 383**

**Customer**

**Facility Name:** Hilton Garden Inn  
**Address:** 9600 University Blvd  
Pittsburgh, PA 15108

**Matrix:** Hilton Garden Inn

**Source Type:** Spa

**Sample Collection**

**Date:** 6/30/26  
**Time:** 12:29 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/2/26  
**Time:** 11:00 AM  
**Analyst:** AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                       |          |          |         |          |    |          |
|-----------------------|----------|----------|---------|----------|----|----------|
| Escherichia Coli:     | Absent   | Absent   | 7/1/26  | 10:30 AM | AH | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls | 7/1/26  | 10:30 AM | AH | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml   | 6/30/26 | 4:45 PM  | AH | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |        |         |    |          |
|---------------------|----------|----------|--------|---------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/1/26 | 2:10 PM | MH | SM 9230C |
|---------------------|----------|----------|--------|---------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|            |          |                |         |          |    |        |
|------------|----------|----------------|---------|----------|----|--------|
| pH:        | 7.6 SU   | 7.2 - 7.8 SU   | 6/30/26 | 12:29 PM | AH | DPD    |
| Chlorine:  | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/30/26 | 12:29 PM | AH | DPD    |
| Turbidity: | 1 NTU    | 1 - 2 NTU      | 6/30/26 | 12:29 PM | AH | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)