



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2764

Customer

Facility Name: *Idlewild and SoakZone*

Address: *2574 Rt 30 E*
Ligonier, PA 15656

Matrix: *Recreational Water*

Source Type: *Baby*

Sample Collection

Date: *6/29/26*

Time: *2:08 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/1/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/30/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/30/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/29/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/29/26	2:08 PM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/29/26	2:08 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/29/26	2:08 PM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)