



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 2730

Customer

Facility Name: Monessen Elks
Address: 70 Pioneer Dr.
Monessen, PA 15062

Sample Collection

Date: 6/29/26
Time: 11:40 AM
Method: Grab

Sample Final Analysis

Date: 7/1/26
Time: 12:30 PM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/30/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/30/26	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/29/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/29/26	11:40 AM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/29/26	11:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/29/26	11:40 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)