



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2765

Customer

Facility Name: *Pike Run Country Club*

Address: *204 Pike Run Road*
Jones Mills, PA 15646

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/29/26*

Time: *9:45 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/1/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/30/26	10:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/30/26	10:30 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	6/29/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/29/26	9:45 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/29/26	9:45 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/29/26	9:45 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor