



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2410

Customer

Facility Name: *Pittsburgh Field Club*

Address: *121 Field Club Road
Pittsburgh, PA 15238*

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *7/2/26*

Time: *8:24 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/3/26*

Time: *12:30 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/26	12:10 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/26	12:10 PM	AH	SM 9222B
Standard plate count:	120/ml	200/ml	7/1/26	4:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/2/26	8:24 AM	SL	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	7/2/26	8:24 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/26	8:24 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor