



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 2648

Customer

Facility Name: *Promise Camp*

Address: *227 Lance Rd.*
Clinton, PA 15026

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/30/26*

Time: *1:57 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/2/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/26	4:45 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/30/26	1:57 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/30/26	1:57 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/26	1:57 AM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)