



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2747

Customer

Facility Name: Seven Oaks C.C.

Address: 132 Lisbon Road
Beaver, PA 15009

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 6/29/26

Time: 2:45 PM

Method: Grab

Sample Final Analysis

Date: 7/1/26

Time: 12:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/30/26 11:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/30/26 11:30 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	6/29/26 5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/29/26 2:45 PM	AMH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/29/26 2:45 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/29/26 2:45 PM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)