



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-14**

**Lab# 428**

**Customer**

**Facility Name:** Upper St. Clair High School

**Address:** 1825 McLaughlin Run Rd.  
Upper St. Clair, PA 15241

**Matrix:** Recreational Water

**Source Type:** Lap Deep

**Sample Collection**

**Date:** 7/1/26

**Time:** 11:09 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/3/26

**Time:** 12:00 PM

**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/2/26               | 11:30 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/2/26               | 11:30 AM | AH      | SM 9222B |
| Standard plate count: | 20/ml    | 200/ml          | 7/1/26               | 4:20 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.3 SU   | 7.2 - 7.8 SU    | 7/1/26    | 11:09 AM | SL      | DPD    |
| Chlorine:      | 0.0 mg/l | 1.0 - 5.0 mg/l  | 7/1/26    | 11:09 AM | SL      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/1/26    | 11:09 AM | SL      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor