



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 314

Customer

Facility Name: UPMC Sports Rehab - South

Address: 3200 S. Water St
Pittsburgh, PA 15203

Matrix: Recreational Water

Source Type: Therapy Spa

Sample Collection

Date: 6/29/26

Time: 9:30 AM

Method: Grab

Sample Final Analysis

Date: 7/1/26

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/30/26	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/30/26	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/29/26	3:11 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/30/26	2:00 PM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/29/26	9:30 AM	JB	DPD
Chlorine:	0.4 mg/l	1.0 - 5.0 mg/l	6/29/26	9:30 AM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/29/26	9:30 AM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor