



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 2602

Customer

Facility Name: Woodridge Condos
Address: 100 Woodridge Circle
Pittsburgh, PA 15234

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/29/26
Time: 11:00 AM
Method: Grab

Sample Final Analysis

Date: 7/1/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/30/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/30/26	11:00 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	6/29/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/29/26	11:00 AM	AHV	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/29/26	11:00 AM	AHV	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/29/26	11:00 AM	AHV	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)