



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2563

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Waterford Landing*
Address: *1200 Landing Ln.*
 Moon Twp, PA 15108

Sample Collection
Date: *6/29/26*
Time: *8:55 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis
Date: *7/1/26*
Time: *12:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/30/26	11:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/30/26	11:30 AM	MH	SM 9222B
Standard plate count:	5700/ml	200/ml	6/29/26	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/29/26	8:55 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/29/26	8:55 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/29/26	8:55 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor