



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2005

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Accord -Avonworth
Address: 498 Camp Horne Road
Pittsburgh, PA 15237

Date: 6/29/26
Time: 1:10 PM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Shallow End

Date: 7/1/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/30/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/30/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/29/26	4:30 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/29/26	1:10 PM	IS	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/29/26	1:10 PM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/29/26	1:10 PM	IS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor