



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2105

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Christopher Wren Apt.* **Sample Collection**
Date: 6/30/26
Address: *501 Christopher Wren Dr.* *Time:* 10:10 AM
Wexford, PA 15090 *Method:* *Grab*

Matrix: *Recreational Water* **Sample Final Analysis**
Date: 7/2/26
Source Type: *Pool* *Time:* 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/26	10:00 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/26	10:00 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/26	4:45 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/30/26	10:10 AM	IS	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/30/26	10:10 AM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/26	10:10 AM	IS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)