



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2172

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Edgeworth Club*

Date: *7/1/26*

Address: *511 East Drive*
Sewickley, PA 15143

Time: *1:00 PM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *7/3/26*

Source Type: *Pool*

Time: *12:00 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/26	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/26	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/26	4:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/1/26	1:00 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/26	1:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/26	1:00 PM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)