



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2681

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Georgetown Commons*
Address: *400 Williamsburg Lane*
 Export, PA 15632

Sample Collection

Date: *6/30/26*
Time: *4:20 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *7/2/26*
Time: *2:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/26	2:10 PM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/26	2:10 PM	MH	SM 9222B
Standard plate count:	5700/ml	200/ml	6/30/26	6:40 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/26	4:20 PM	DW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/30/26	4:20 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/26	4:20 PM	DW	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)