



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2637

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Arsenal 201 Phase 1*

Address: *3922 Foster St.*
 Pittsburgh, PA 15201

Date: *6/29/26*
Time: *2:30 PM*
Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Source Type: *Pool 1*

Date: *7/1/26*
Time: *11:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/30/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/30/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/29/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/29/26	2:30 PM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/29/26	2:30 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/29/26	2:30 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor