



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2384

Customer

Facility Name: Ormsby
Address: 79 S. 22nd St.
Pittsburgh, PA 15203

Sample Collection

Date: 6/30/26
Time: 11:30 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/2/26
Time: 10:30 AM
Analyst: AS

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/26 10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/26 10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/26 3:44 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/30/26 11:30 AM	WB	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	6/30/26 11:30 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/26 11:30 AM	WB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)