



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 244

Customer

Facility Name: Oliver H.S.

Address: 2323 Brighton Rd.
Pittsburgh, PA 15212

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 6/29/26

Time: 1:41 PM

Method: Grab

Sample Final Analysis

Date: 7/1/26

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	6/30/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	6/30/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	A	6/29/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	6/29/26	1:41 PM	JT	DPD
Chlorine:	3.0 mg/l	A	6/29/26	1:41 PM	JT	DPD
Turbidity:	1 NTU	A	6/29/26	1:41 PM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)