



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-17

Lab# 2769

Customer

Facility Name: *Candlewood Suites*

Address: *37 Holiday Blvd*
Mercer, Pa 16137

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/21/26*

Time: *9:40 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/24/26*

Time: *12:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/26	11:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/26	11:50 AM	AS	SM 9222B
Standard plate count:	570/ml	200/ml	7/21/26	6:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/21/26	9:40 AM	MM	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/21/26	9:40 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/26	9:40 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor