



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 489

Customer

Facility Name: Center for Fitness and Health

Address: 800 Plaza Dr. Suite 100
Bell Vernon. Pa 15012

Matrix: Recreational Water

Source Type: Lap Pool

Sample Collection

Date: 7/21/26

Time: 3:15 PM

Method: Grab

Sample Final Analysis

Date: 7/24/26

Time: 12:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/26	11:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/26	11:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/26	6:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/26	3:15 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/21/26	3:15 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/26	3:15 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)