



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 131

Customer

Facility Name: Hampton Inn Settlers Ridge

Address: 5000 Campbell's Run Road
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/22/26

Time: 9:35 AM

Method: Grab

Sample Final Analysis

Date: 7/25/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/26	10:10 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/26	10:10 AM	MH	SM 9222B
Standard plate count:	570/ml	200/ml	7/22/26	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/26	9:35 AM	JB	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/26	9:35 AM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/26	9:35 AM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor