



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 160**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *810 Highland Meadow Dr.*  
*Washington, PA 15301*

**Sample Collection**

**Date:** *7/22/26*  
**Time:** *3:40 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*  
**Source Type:** *Spa*

**Sample Final Analysis**

**Date:** *7/25/26*  
**Time:** *11:30 AM*  
**Analyst:** *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------------|---------------|
|----------------------------|----------------|------------------------|-----------------------------|----------------|---------------|

|                       |          |          |         |          |    |          |
|-----------------------|----------|----------|---------|----------|----|----------|
| Escherichia Coli:     | Absent   | Absent   | 7/23/26 | 11:10 AM | AH | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls | 7/23/26 | 11:10 AM | AH | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml   | 7/22/26 | 6:30 PM  | SL | SM 9215B |

| <b>Additional Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------------|---------------|
|----------------------------|----------------|------------------------|-----------------------------|----------------|---------------|

|                     |          |          |         |          |    |          |
|---------------------|----------|----------|---------|----------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/23/26 | 11:40 AM | AH | SM 9230C |
|---------------------|----------|----------|---------|----------|----|----------|

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|----------------|---------------|
|-----------------------|----------------|------------------------|------------------|----------------|---------------|

|            |          |                |         |         |     |        |
|------------|----------|----------------|---------|---------|-----|--------|
| pH:        | 7.6 SU   | 7.2 - 7.8 SU   | 7/22/26 | 3:40 PM | AHV | DPD    |
| Chlorine:  | 5.0 mg/l | 1.0 - 5.0 mg/l | 7/22/26 | 3:40 PM | AHV | DPD    |
| Turbidity: | 1 NTU    | 1 - 2 NTU      | 7/22/26 | 3:40 PM | AHV | Visual |

**Sample comments**

*Andre Smith*

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)