



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2398

Customer

Facility Name: *Pennsbury Village*

Address: *1039 Pennsbury Blvd.*
Pittsburgh, PA 15205

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *7/22/26*

Time: *10:14 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/25/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/26	10:40 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/26	10:40 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	7/22/26	10:14 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/26	10:14 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/26	10:14 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor