



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2399

Customer

Facility Name: Pennsbury Village
Address: 1039 Pennsbury Blvd.
Pittsburgh, PA 15205

Sample Collection

Date: 7/22/26
Time: 10:14 AM
Method: Grab

Sample Final Analysis

Date: 7/25/26
Time: 11:00 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/26 10:40 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/26 10:40 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/26 5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	7/22/26 10:14 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/26 10:14 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/26 10:14 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor