



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 2648

Customer

Facility Name: *Promise Camp*

Address: *227 Lance Rd.*
Clinton, PA 15026

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/21/26*

Time: *10:24 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/24/26*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/26	9:40 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/26	9:40 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/26	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/21/26	10:24 AM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/26	10:24 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/26	10:24 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)