



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2495

Customer

Facility Name: South Hills Country Club

Address: 4305 Brownsville Road
Pittsburgh, PA 15236

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 7/21/26

Time: 11:10 AM

Method: Grab

Sample Final Analysis

Date: 7/24/26

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/26	11:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/26	11:50 AM	AS	SM 9222B
Standard plate count:	30/ml	200/ml	7/21/26	6:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/21/26	11:10 AM	AHV	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/21/26	11:10 AM	AHV	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/26	11:10 AM	AHV	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor