



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2501

Customer

Facility Name: Spring Run Condo
Address: Spring Run Dr.
Monroeville, PA 15146

Sample Collection

Date: 7/21/26
Time: 10:23 AM
Method: Grab

Sample Final Analysis

Date: 7/24/26
Time: 1:00 PM
Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/26	12:40 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/26	12:40 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/26	6:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/26	10:23 AM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/21/26	10:23 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/26	10:23 AM	DW	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)