



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 340

Customer

Facility Name: Winchester Apts
Address: 540 N. Neville St.
Pittsburgh, PA 15213

Sample Collection

Date: 7/20/26
Time: 12:45 PM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/23/26
Time: 10:30 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/21/26	10:15 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/21/26	10:15 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	7/20/26	5:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/20/26	12:45 PM	AG	DPD
Chlorine:	6.2 mg/l	1.0 - 5.0 mg/l	7/20/26	12:45 PM	AG	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/20/26	12:45 PM	AG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)