



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2597

Customer

Facility Name: Woodland Hills Club
Address: 2799 Bingham Drive
Upper St. Claire, PA 15241

Sample Collection

Date: 7/22/26
Time: 8:05 AM
Method: Grab

Matrix: Recreational Water

Source Type: Deep End

Sample Final Analysis

Date: 7/25/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/26	9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/26	9:40 AM	AH	SM 9222B
Standard plate count:	200/ml	200/ml	7/22/26	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/26	8:05 AM	JB	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/22/26	8:05 AM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/26	8:05 AM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor