



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2606

Customer

Facility Name: Wyngate Swim Club
Address: 100 North Jamestown Rd.
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 7/20/26
Time: 9:02 AM
Method: Grab

Sample Final Analysis

Date: 7/23/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/21/26 10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/21/26 10:50 AM	AS	SM 9222B
Standard plate count:	170/ml	200/ml	7/20/26 6:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/20/26 9:02 AM	AMH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/20/26 9:02 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/20/26 9:02 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)