



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2562

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Waterford at Nevillewood*
Address: *1900 Tee Court*
 Presto, PA 15142

Sample Collection

Date: 7/22/26
Time: 2:15 PM
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: 7/25/26
Time: 10:30 AM

Source Type: *Pool*

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/26	10:10 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/26	10:10 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/26	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/22/26	2:15 PM	JB	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/22/26	2:15 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/26	2:15 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor