



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 155

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Holiday Inn*
Address: *20 S 10th St.*
Pittsburgh, PA 15203

Sample Collection

Date: *7/20/26*
Time: *11:20 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *7/23/26*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/21/26	9:20 AM	AS	SM 9222G

Total coliforms:	0/100mls	2/100mls	7/21/26	9:20 AM	AS	SM 9222B
------------------	----------	----------	---------	---------	----	----------

Standard plate count:	0/ml	200/ml	7/20/26	3:37 PM	AH	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
----------------	---------	-----------------	-----------	--	---------	--------

pH:	7.5 SU	7.2 - 7.8 SU	7/20/26	11:20 AM	MB	DPD
-----	--------	--------------	---------	----------	----	-----

Chlorine:	2.6 mg/l	1.0 - 5.0 mg/l	7/20/26	11:20 AM	MB	DPD
-----------	----------	----------------	---------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	7/20/26	11:20 AM	MB	Visual
------------	-------	-----------	---------	----------	----	--------

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor