



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2652

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Kane @ Grey's Landing*

Address: *2971 Kane Road*
Aliquippa, PA 15001

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/20/26*

Time: *11:28 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/23/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/21/26	10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/21/26	10:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	7/20/26	6:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/20/26	11:28 AM	AHM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/20/26	11:28 AM	AHM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/20/26	11:28 AM	AHM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor