



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2638

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Rivers Edge Condo*

Address: *Allegheny Ave*
Oakmont, PA 15139

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: 7/20/26

Time: 8:30 AM

Method: *Grab*

Sample Final Analysis

Date: 7/23/26

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/21/26	9:20 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/21/26	9:20 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	7/20/26	3:37 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/20/26	8:30 AM	LL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/20/26	8:30 AM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/20/26	8:30 AM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor