



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2258

Customer

Facility Name: Highland Park Club
Address: 151 Lake Dr.
Pittsburgh, PA 15206

Sample Collection

Date: 7/21/26
Time: 2:45 PM
Method: Grab

Sample Final Analysis

Date: 7/24/26
Time: 10:00 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/26	9:40 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/26	9:40 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/26	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	7/21/26	2:45 PM	WB	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/21/26	2:45 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/26	2:45 PM	WB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)