



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 4**

Lab# 2565

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:* Waterfront

*Address:* 611 E. Waterfront Dr.  
Munhall, PA 15120

*Matrix:* Recreational Water

*Source Type:* Pool

**Sample Collection**

*Date:* 7/29/26

*Time:* 11:30 AM

*Method:* Grab

**Sample Final Analysis**

*Date:* 8/1/26

*Time:* 10:00 AM

*Analyst:* AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/30/26              | 9:30 AM | MD      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/30/26              | 9:30 AM | MD      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/29/26              | 5:45 PM | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 7/29/26   | 11:30 AM | JB      | DPD    |
| Chlorine:      | 7.5 mg/l | 1.0 - 5.0 mg/l  | 7/29/26   | 11:30 AM | JB      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/29/26   | 11:30 AM | JB      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor