



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2607

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Yards @ 3 Crossings*
Address: *2645 Railroad St.*
 Pittsburgh, PA 15222

Sample Collection

Date: 7/28/26
Time: 9:00 AM
Method: Grab

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: 7/31/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/26	10:40 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/26	10:40 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/26	6:00 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/28/26	9:00 AM	JB	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/26	9:00 AM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/26	9:00 AM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor