



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2808**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Facility Name:**      *Rose Ridge*  
**Address:**      *101 Freedom Rd.*  
*Allison Park, PA 15101*

**Sample Collection**

**Date:**      6/29/26  
**Time:**      1:57 PM  
**Method:**      *Grab*

**Matrix:**      *Recreational Water*  
**Source Type:**      *Spa*

**Sample Final Analysis**

**Date:**      7/1/26  
**Time:**      1:00 PM  
**Analyst:**      AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/30/26              | 12:30 PM | MH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/30/26              | 12:30 PM | MH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/29/26              | 6:30 PM  | SL      | SM 9215B |
| Additional Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls | 2/100mls        | 6/30/26              | 2:00 PM  | AH      | SM 9230C |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 6/29/26   | 1:57 PM | MM      | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 6/29/26   | 1:57 PM | MM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/29/26   | 1:57 PM | MM      | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)