



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 3737

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Prism at Diamond Ridge*
Address: *1000 Prism Place*
Moon Twp. PA 15108

Sample Collection

Date: 7/7/26
Time: 11:00 AM
Method: Grab

Matrix: *Recreational Water*
Source Type: *Spa*

Sample Final Analysis

Date: 7/9/26
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/26	8:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/26	8:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/26	3:30 PM	AH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/7/26	11:00 AM	VH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/26	11:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/26	11:00 AM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)