



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2751**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Facility Name:**      *Regency*  
**Address:**      *1785 McKees Rock Rd.*  
*McKees Rocks, PA 15136*

**Sample Collection**

**Date:**      *7/8/26*  
**Time:**      *8:30 AM*  
**Method:**      *Grab*

**Matrix:**      *Recreational Water*  
**Source Type:**      *Pool*

**Sample Final Analysis**

**Date:**      *7/10/26*  
**Time:**      *9:00 AM*  
**Analyst:**      *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/9/26               | 8:30 AM | MD      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/9/26               | 8:30 AM | MD      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/8/26               | 4:00 PM | MH      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 7/8/26    | 8:30 AM | VH      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 7/8/26    | 8:30 AM | VH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/8/26    | 8:30 AM | VH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor