



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 120

Customer

Facility Name: Wingate

Address: 210 Executive Dr.
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 5/5/26

Time: 12:40 PM

Method: Grab

Sample Final Analysis

Date: 5/8/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/6/26 10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/6/26 10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	5/5/26 4:47 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/6/26 12:30 PM	JC	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	5/5/26 12:40 PM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/5/26 12:40 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/5/26 12:40 PM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)