



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 160

Customer

Facility Name: *Holiday Inn Express*
Address: *810 Highland Meadow Dr.*
Washington, PA 15301

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *5/5/26*
Time: *12:28 PM*
Method: *Grab*

Sample Final Analysis

Date: *5/8/26*
Time: *11:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/6/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/6/26	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	5/5/26	5:50 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/6/26	12:30 PM	JC	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.2 SU	7.2 - 7.8 SU	5/5/26	12:28 PM	JMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/5/26	12:28 PM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/5/26	12:28 PM	JMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)